

STATE OF TENNESSEE TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION COOKEVILLE ENVIRONMENTAL FIELD OFFICE

1221 South Willow Avenue Cookeville, Tennessee 38506 Statewide 1-888-891-8332

Phone 931-520-6688

Fax 931-432-6952

The Honorable Donny Dennis City of Carthage P.O. Box 259

January 24, 2017

RE: Collection System Inspection (CSI), City of Carthage Wastewater Treatment Plant; NPDES TN0022993

Dear Mayor Dennis:

Carthage, TN 37030

Division of Water Resources staff wishes to thank you, and Mr. Ricky Brown for your generous time and courtesy during the recent Collection System/Pump Station Inspection (CSI) at the City of Carthage Wastewater Treatment Facility in Smith County.

Permit

The current NPDES permit became effective on March 1, 20016 and will expire on February 28, 2019. The single outfall is at the river bank (U.S. Corps of Engineer's property) of the Cumberland River (Old Hickory Reservoir). The NPDES sign was in place.

Facility Site Review

The wastewater treatment process was in operation. The facility was clean. The tanks within the facility appeared to be in good condition as recent maintenance activities have improved operation.

Effluent and Receiving Waters

The receiving waters were found to be in good condition. The effluent was observed and noted to be clear.

Laboratory

It was previously recommended that the City consider purchasing or budgeting for a Luminescent Dissolved Oxygen (LDO) meter to be used in the Carthage STP laboratory. The purchase was made and the operators are impressed with the performance of the new instrument.

The Honorable Donny Dennis Mayor City of Carthage 1/24/17 Page 2

Operations and Maintenance

A portion of the collection system was specifically reviewed. Pump station maintenance was being performed by the City's contractor on the STP's internal pump station. A bypass pump was in place. The Radio Station pump station (recently refurbished) was reviewed. This new pump station is still within the warranty period. Problems at this pump station were noted with the starting mechanism for one of the two pumps. The telemetry at this pump station is performing well. The flow measurement at the pump station is working well. A recent electrical failure due to a bird shorting the power feed on the electrical service proved to be a good example of how fast the pump station could be brought back on line. After the power failure, the system was back on line within thirty (30) minutes.

Recommendations

- ✓ Maintain the ongoing maintenance activities at the wastewater plant and collection system including head-works improvements.
- ✓ Please continue to provide Operators with the knowledge of changing issues through the attendance of courses at the Fleming Training Center.

The Division of Water Resources would again like to thank you and Mr. Ricky Brown for your time and courtesy during this inspection.

If you have any questions, you may contact Oakley Hall in Cookeville by way of telephone at (931) 432-6677 or toll free at 1-(888)-891-8332. You may also use electronic mail at: Oakley.Hall@tn.gov.

Sincerely,

Johnny K. Walker

Environmental Program Manager III

John K. Wall

Division of Water Resources

Cookeville Environmental Field Office

Enclosure: Site Photographs; Water Compliance Inspection Report;

cc: EFO-CK, Smith County DWR Files: TN0022993



TDEC - Division of Water Resources Cookeville Field office

ICIS NPDES Facilities Inspection Report

The second second				Fa	cility Data	ban.	No. 14		181 - 181	16 8 77 17	
NPDES ID: TN002	22993		Facility Site Name	City of Carthage Sewer Treatment Plant							
			Address	Address P.O. Box 259							
Permit Eff. Date: Mar 1, 2016			Permit Exp Date	: Feb 28,	2019		<u>-</u>	SIC Code:			
			Comp	liance M	lonitoring Info	rma	ntion				
Compliance Monitoring Activity Name CSO Inspection				n-Sampling	<u></u> j)						
		* If B	io Monitoring is se	lected abo	ve, select the meth	od u	sed:				
Compliance Monitoring Activity Evaluation			/aluation								
			Compl	iance M	onitoring Date	es/T	imes				
Entry Date/Time (mm/dd/yyyy hh:mm): January 13, 2			anuary 13, 2016; 12	6; 12:30 PM Exit Date/Time (mm/dd/yyyy hh:mm)			m): Janua	January 13, 2016; 2:30 PM			
				Facility	Representative	es				ozdi Şaraya	
Mr. Ricky Brown, Cl	hief Oper	ator		Mayor Donny Dennis							
On-Site Representa	ative(s)Tit	le, Phone Num	nber	Responsible Official(s), Title, Phone Number							
	No.	in the	Statu	ute and	Section Inform	natio	on	200	150 31 11		
Federal Statute:	CWA -	Clean Water Ad	et	State Statute: Tennessee			nnessee Water	ter Quality Control Act			
Programs:	NPDES-	Base Program	(Limits, Reporting	, & Schedu	ıle)						
Compliance Monitoring Reason: Core Progra				<u> </u>							
Compliance Monitoring Agency Type: State				Agency Name				ne: TDEC	e: TDEC - DWR		
Did EPA assist/ Inspection? No				Time Physically conducting activity: Days: 3				3	Hours:	0	
Inspection Type: State				Compliance Monitoring Action Outcom				: No Violation			
Lead Agency: State				Compliance Monitoring Rating Code:				Unrated			
If Joint Inspection, v	what was			N/A		N-0.			- 10 po - 27 II - 2		
		Areas Eva	aluated During	Inspec	tion (Check on	ly th	ose areas e	valuated)	Sharp in the		
□ Permit] Permit			Self - Compliance Program				Pretreatment			
Records / Records			Cor	Compliance Schedule				Pollution Prevention			
☐ Facility Site Review			⊠ Lab	Laboratory				Storm Water			
			⊠ Ор	Operations & Maintenance				Combined Sewer Overflow			
Flow Measurement			☐ Slu	Sludge Handling / Disposal		\boxtimes	Sanitary Sewer Overflow				
	VEE.	191151 2 1	Comp	liance N	Monitoring Sur	mma	ary		reconsenses.		
Collection System In	spection	in order to rew									
	70 WW	A WALLSON	FPA	and Sta	ite Representa	tive			/100 July 117	a Hieseku n	
William O. Hall				TDEC, DWR/ Cookeville EFO/ (931) 520-6677				Jan 2	Jan 20, 2017		
Inspector's Signature				Agency / Office / Phone				Date			
Johnny K. Walker Walker				TDEC, DWR/ Cookeville EFO/ (931) 520-6688					Jan 20, 2017		
Manager's Signature				Agency / Office / Phone				Date	4		



STATE OF TENNESSEE TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION COOKEVILLE ENVIRONMENTAL FIELD OFFICE

1221 South Willow Avenue Cookeville, Tennessee 38506 Statewide 1-888-891-8332

Phone 931-520-6688

Fax 931-432-6952

City of Carthage Collection System Photo Sheet, January 13, 2017





The City's contractor was performing pump station maintenance. A gasoline powered bypass pump was in place to move sewer around to the downstream manhole. This is the internal pump station at the sewer treatment plant. Photos Recorded on: 1/13/17, by: WOH





The "Radio Station" pump station tower is pictured along with the new placement of the submerged pumps. It was noted that one of the two pumps is having difficulty starting. The operators noted that they like the new telemetry that is now in place. Photo recorded 1/13/17, by: WOH